



**ADDENDUM NO. #2**

**DATE: August 7, 2017**

**INVITATION FOR BID (IFB): H170026483 – Richmond Ambulance Authority Canopy Project**

**DATED: July 17, 2017**

**RECEIPT DATE: August 8, 2017 / Time: 2:30 P.M.**

**OPENING DATE: August 9, 2017 / Time: 2:30 P.M.**

**SUBJECT: Questions and Answer**

Ladies/Gentlemen:

Please take note of the following:

1. Q: The electrical plans seem to indicate that there are existing raceways from the new lighting locations to the power source. Can this be confirmed as correct?

A: The contractor is responsible for a complete installation including, but not limited to, all conduit and conductors.

Vendor must take due notice and be governed accordingly. This addendum must be acknowledged and included with the bid submission as indicated in the IFB or your response may not be considered.

Sincerely,

*Cornelius Hunt Sr.*

Cornelius Hunt Sr., VCO  
Contract Specialist