



ADDENDUM NO. 1

DATE: February 8, 2012
INVITATION FOR BID: K12097-1 – Richmond Public Library Main Branch Elevator
and Fire Alarm Upgrades
DATED: January 23, 2012
RECEIPT DATE: March 7, 2012 (UNCHANGED)
OPENING DATE: March 8, 2012 (UNCHANGED)
SUBJECT: Specification Changes/Clarification & Questions/Answers

Ladies/Gentlemen:

Please take note of the following:

Specification Changes/Clarifications:

1. Specification Cover Sheet for Main Library Fire Alarm Upgrade is attached. The electronic copy of specifications on the FTP site has the incorrect specification cover sheet.
2. Specification Section-Raceway and Boxes
 - a. Paragraph 3.1, B, 1.-Add the following: Exposed vertical raceway in all areas except mechanical/electrical rooms shall be 'Surface Metal Raceway'
3. Specification Section –Fire Alarm 268311
 - a. Paragraph 2.8, A.- Add the following: The Network Input Output Nodes (NION) shall be provided in this contract. The NION is required to connect the new Master Fire Alarm Control Unit to the existing Notifier Onyx system.
4. Specification Section –Fire Alarm 268311
 - a. Part 3- Add the following paragraph 3.9: Programming of Existing Notifier Onyx network server located at City Hall. The contractor shall include installation of the Main Library building floor plans and device graphics on to the existing system. The Onyx screen shall display individual alarms and trouble signals for all devices in the Main Library.

Questions/Answers:

1. **Will Simplex Grinnell be allowed to bid the project?**

Answer: Yes, Simplex Grinnell will be allowed to bid. The system must meet the requirements of the contract documents.

Vendor must take due notice and be governed accordingly. This addendum must be acknowledged as indicated in the Bid Book or your bid may not be considered.

Sincerely,

Kristina Jones

Kristina Jones

Contract Specialist

804/646-5802

BID DOCUMENTS




CITY OF RICHMOND MAIN LIBRARY FIRE ALARM UPGRADE


City of Richmond
Department of Public Works
Richmond, Virginia

Dewberry # 50043784

AUGUST 15, 2011



Prepared by:

 **Dewberry**
2301 Rexwoods Drive, Suite 200
Raleigh, NC 27607
Phone: (919) 881-9939
Fax: (919) 881-9923
www.dewberry.com