



ADDENDUM NO. 1

DATE: July 27, 2017
INVITATION FOR BID: IFB H170025907 – Ductile & Cast Iron and Water Pipe Fittings
DATED: July 16, 2017
RECEIPT DATE: August 2, 2017 @ 11:00 A.M. (Changed)
OPENING DATE: August 2, 2017 @ 11:00 A.M. (Changed)
SUBJECT: Due Date and Opening Date/Specification Update/Questions and Answers

Ladies/Gentlemen:

Please take note of the following:

Receipt Date and Opening Date Change

1. The Bid Receipt Date is changed to **August 2, 2017 @ 11:00 A.M. (Changed)**.
The Bid Opening Date is change to **August 2, 2017 @ 11:00 A.M. (Changed)**

PART 1 – SPECIFICATIONS:

1. Section 3 City Requirements, Subsection H shall be revised to read as follow:

Thickness

Unless otherwise specified, the pipe thickness shall be as follow:

Size (inches)	Thickness Class	Thickness (inches)
3	52	.28
4	53	.32
6	54	.37
8	54	.39
10	52	.35
12	52	.37
16	51	.37
20	51	.39
24	51	.41
30	51	.43
26	51	.48
42	51	.53
48	51	.58

Question/Answers

1. Q. The Bid is asking for CL51 on some of the pipe line items, however the specs have a thickness schedule of C152. Should I quote off of spec or off of the material listed?

A. [The quote should be on the material listed on the bid form \(please see Section h. addendum\)](#)

2. Q. In the specifications Mechanical Joint fittings refers to ANSI standard A21.10, which is a C110 full body spec. Is this correct?

A. **Yes.**

3. Q. Bid - Specifications Part I - denotes C110 full body MJ fittings per Fittings - section a. To our knowledge City of Richmond generally requires MJ C153 compact fittings. We would like to request confirmation that the City would like C110 fitting quoted for this IFB?

A. **The specification noting the C110 Specification (full body fittings) is the City of Richmond standard it seeks to have quoted.**

4. Q. Are the estimated quantities Annual estimated quantities?

A. **The estimated quantities reflect historical data and projected utilization estimates, and cannot be guaranteed to be met, surpassed or decreased.**

Vendor must take due notice and be governed accordingly. This addendum must be acknowledged and included with the bid submission as indicated in the IFB or your response may not be considered.

Sincerely,

Cornelius Hunt Sr.

Cornelius Hunt Sr., VCO
Contract Specialist
804/646-5820

RESPECTFULLY SUBMITTED:

Company

BY: _____

Title

Date